DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Diane Kimball + Richard Kimball APPLICANT:
ADDRESS: P.O. Box 5281 APPLICATION DATE: 5 27 99 DATE EVALUATED: 6 14 99
PROPOSED FACILITY: 3 bd Rm Mobile Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 8.05 Ac.
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 15%	0-20	SBK CL	FI FR					PS .3
		20-36	SBK C/SAP Inclusions	FR					
		36+	SAP						
2	L 15-20%	0-12	SBK C CL	FR					U-PS .6
		12+	SAP						
3	S N 15%	0-24	SL SCL	FR-VFR					U PS
		24+	SAP						
4	S 10%	0-24	SBK C	FI SS SAP					PS .3
		24-30	SBK C/SAP	FI FR					
		30+	SAP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: