No Copy

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Phil Eller DATE 4/15/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 to Don Murdocks Svc Sta. T.L. on Lizard Rd. 2nd House on L - Past Rosemans Trailer Park R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil _____

Percolation Rate _____

Topography Repair

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines —

Sq. Ft. — Linear Ft. —

Depth of Stone in Lines —

Water Supply: Individual ( )

Public ( )

Installed by Hoke Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: Old Tank Collapsed and New Tank installed. No Repair on Lines

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 4/15/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold