IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lawrence [redacted] Hess DATE June 13, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90, T.L. on Lippard Road at Don Murdocks' Store, Trailer Park on left

SUBDIVISION NAME Roseman Trailer Park LOT NO. 3 S. R. No. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area acreage

Character & Porosity of Soil Red Clay
Percolation Rate Satisfactory
Topography Slight
Depth to Water Table Low
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by North Iredell Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic installed 4/12/77, originally inspected by E.A. Stevens, septic not surfacing at time of inspection

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 6/13/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold