IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Merris Rosemon DATE 4-12-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90. T.L. on Liffard Rd at Don Murdocks Store Trailer Park on L. S. R. No. _____

SUBDIVISION NAME Rosemon Trailer Park LOT NO. 9 & 10 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area Acreage

Character & Porosity of Soil Red Clay
Percolation Rate Satisfactory
Topography Level
Depth to Water Table Low
Rock or other impervious formations None



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by North Iredell Septic Tank Co.

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: Platted and approved Prior to Dec 5, 1973

CERTIFICATE OF COMPLETION BY E. G. Stevenson Andrew Cawsey DATE 4-12-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold