IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Morris Roseman DATE 11/14/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Roseman Trailer Park on Liddard Road #1521
1st Tank on Rt of New addition

SUBDIVISION NAME Morris Roseman Trailer Park LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____


House ( ) Mobile Home (2) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lines are Deep.

CERTIFICATE OF COMPLETION BY E. G. Stutenson DATE 11/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold