1985.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DAVID PEGRAM DATE 9-20-90 PERMIT NO. ST-A-58

PHONE: Business _____ Home _____

LOCATION Hwy 90 W-T.L. on Leland Ford Rd.-T.R. on Tippah Farm Rd.-T.R. on Mosley Rd.-T.L. on 1st st. go Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

DOUBLEWIDE

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil Loam Suitable

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 4 Min/Inch

Auto. Dishwasher Yes (✓) No ( ) Topography Level

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations Saprolite at 24"

Lot Area 7.81 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:


No. of Lines 5

Sq. Ft. 300 Linear Ft. 300

Depth of Stone in Liner 24"

Water Supply: Individual (✓)

Public ( )



Plot of System

Installed by Dennis Hallibee

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Hedrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Bates DATE 7-31-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold