DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Eric Thompson APPLICANT: 3BR mH
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9/30/a
PROPOSED FACILITY: 3BR mH Yr PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.66 Ac.
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	10% Linear	0-4	sl	SBK VFR SS SP SE Ex					PS .3
		4-48	sc l/sa	SBK VFR SS SP SE Ex					
2	12% Linear	0-8	sl	Mod SBK SS SP SE Ex dk Brn					PS .3
		8-28	sl	SBK SS SP SE Ex					
		28-48	cl w/ sa	Mod SBK SS SP SE Ex					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Ground 25% Red	Part of 50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Job
OTHER(S) PRESENT: _____