IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (or) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 15T863 20 PIN # 4705-91-2376 DATE 8-11-09

OWNER or APPLICANT Cody Shriver / % Freedom Homes, Mountain #667 PHONE: Business Eric Ward cell # 704-746-4728 Home:

OWNER or APPLICANT ADDRESS 197 Titanium Drive, Statesville, NC 28677

LOCATION / DIRECTIONS Hwy 64 West TR Upward Farm Rd TR Steeves Edge Rd TR Emerald Isle TR Zircon Drive TL Titanium Drive Lot on left in Curve

SUBDIVISION Steeves Edge BLOCK / SECTION LOT # 67 LOT AREA 3.11 Acres DESIGN FLOW 360 gpd L.T.A.R. .03 gal/ft²/day

Septic Tank 1000 Gallons: STB 750 Date 2-24-09
Pump Tank Gallons: P T Date
Pump Make Model Serial #
Nitrification Field No Fields 1 No Lines 4 Linear Feet 300 LF/TR
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion/System Type I II III IV V VI
System Description: 25% Reduction
Repair System Description: 25% Reduction
Maintenance Agreement Required ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3
☐ Business No. Persons 4
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☒ Public ☐ Community

Comments / Conditions

Comments / Conditions

INITIAL SITE SKETCH

Please See Attached Sketch for Layout
Follow Contours As Flagged.

AS BUILT SKETCH

Red Tube Septic Marker

3 X 100
3 X 100
3 X 100

3 @ 100'

END Cap Distribution

14
22
4

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Jennie Gallihen Date 8-12-09

Improvement Permit by: Fred Clemmer Date 8-11-09

Authorization to Construct by: Fred Clemmer Date 8-11-09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: A-1 Backhoe

Operation Permit by: Kelly Cook Date: 8-20-09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant