IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 84273 PIN# 4706049908 DATE 11-4-99

OWNER OR CONTRACTOR Gary Davidson PHONE: Business 873 7086 Home

ADDRESS 185 Hippely Farm Rd Sta, N.C.

LOCATION 64 W TL Lackey Fm TR Cherry Blossom 1ST LOT left

SUBDIVISION Richmont Hills BLOCK / SECTION 1 LOT 3 LOT AREA 1.18 acres SITE CLASS PS DESIGN FLOW 360 L.T.A.R. .13

Septic Tank: 1000 Gallons; STB 1012 Date 12/17/98

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Conv. Gravity

Repair System Description:

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees

☐ Other

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☐ Community

Comments:/Conditions:

Cherry Blossom

Comments:/Conditions:

Septic Tank 2 Liters Installed

- Poly Lok Filters Installed

INITIAL SITE SKETCH

294'

Drive 65'

160'

85'

Home 85'

15'

30'

Repair area

AS BUILT SKETCH

S.T.

3' X 100'

3' X 100'

3' X 100'

3' X 100'

3 Flow Dividers

320'

Lackey Rd

*Installed as shown

*Used Distribution box instead of flow dividers

- Health Dept Okayed

wpl

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Gary Davidson date 11-5-99 Installed by: Statesville Backhoe

Improvement Permit by: R.C. moore date 11-4-99 Operation Permit by: William E. Johnson date 6/16/04

Authorization to Construct by: R.C. moore date 11-4-99 Existing System Inspection by: date

HEALTH DEPT. COPY. WHITE OWNER COPY (FINAL). YELLOW OWNER COPY (INITIAL). PINK