DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Jones

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Amos Smith APPLICANT: Sibl Smith
ADDRESS: E Lockey Farm Rd APPLICATION DATE: 12/15/00 DATE EVALUATED: 11/27/00
PROPOSED FACILITY: 3BR mobile home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 10.98
LOCATION OF SITE: 64 West @ Lockey Farm Rd, property 1 mile on left PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	8% Linear	0-6	scl	fr ss sp SExp					1.5 .5 Shallow trenches
		6"-16	c msbk	fi s p SExp					
		16-26	cl msbk	fi s p SExp					
		26-49	sap sc Hard rock	vfr ss sp SExp					
2	Linear 8%	0-4"	scl w sbk	fr ss sp SExp					1.5 .3 Shallow trenches
		4-22"	cl m sbk	fi s p SExp					
		22-32"	sc w sbk	fi s p SExp					
		32-40	sc w/rock	fr ss sp SExp					
		40-48	sap sc						
3	Linear 6% Repair	0-12"	scl	fi ss sp SExp					1.5 .3 Shallow Trenches
		12-20"	cl msbk	fi s p SExp					
		20-42"	cl w sbk	fi s p SExp					
		42"	quartz rock						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1.5	1.5
System Type(s)	Shallow Trench	25% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: [illegible] RSE
OTHER(S) PRESENT: _____