IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Hager & Gene Foy DATE 3/20/80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90 above Scotts School. T.L. just above Barnes Rd #1537. House on Rt S. R. No. _____

SUBDIVISION NAME Cam a Will LOT NO 27-28-29-30 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 15 000


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Slope Low

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Grade lot so surface water will not run or stand over drainfield. Pipe downspouts away from lines This is important. Lines are deep.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3/20/80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold