IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 74253 / 74254 PIN# (4706 38 1089) (4706 38 1089) DATE 6-9-98

OWNER OR CONTRACTOR Iredell Co Schools PHONE: Business 873-3755 Home

ADDRESS Scotts School

LOCATION Hwy 90 W

SUBDIVISION BLOCK / SECTION LOT LOT AREA acreage SITE CLASS. DESIGN FLOW 4125 L.T.A.R.

Septic Tank: 4800 Gallons; STB Date

Dosing Tank ~~Pump Tank~~: 600 Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 2 Square Feet 8250 Linear Feet 2750

No Lines 22 Trench Width 36 Max Trench Bottom Depth 36 Gravel Depth 12

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: large conv 3500 gal +

Repair System Description:

Maintenance Agreement Required: ☐ Yes ☐ No

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms

☐ Business Two No. Employees

☑ Other School / mobile classrm

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☐ Community

Comments:/Conditions:

System Installed 1980 under Dept of Water Quality Inspection.

Comments:/Conditions:

30 student addition for each mobile class room Total 60 students

INITIAL SITE SKETCH

AS BUILT SKETCH

Present Enrollment of 350 students Adding 60 for Total of 410. Entire school was refitted with low flow Fixtures which enables to be calculated at 9 gals/student for Total of 3690 gal/day which is under Design Flow. This information was Provided To Bill Jetton with onsite Staff in Raleigh

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date Installed by:

Improvement Permit by: date Operation Permit by: date

Authorization to Construct by: date Existing System Inspection by: P.C. Moore date 6-9-98

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD