Larry Jenkins - Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Blevins DATE 11-14-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90 above Don Mundecks Sen Sta. T.L. 1st Paved Drive - Bear To R. House on L S. R. No. _____

SUBDIVISION NAME Mar View LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 130 X 190


Character & Porosity of Soil Acceptable

Percolation Rate _____

Topography Slight Slope to back Low

Depth to Water Table _____

Rock or other impervious formations Rotten rock



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Herman Gibson

IMPROVEMENTS PERMIT BY _____

COMMENTS: Some rock in ditch approx 10' each side of distribution box. Divert surface water away from lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-14-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold