IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Moose DATE 12/28/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 to Scotts T.R. on Rd 1562. Go aprox ½ Mile to driveway on L. House back off of Road. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 12½ Acres



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water should be diverted away from Tank & lines.
System Put in in Wet Weather

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/28/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold