DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James D. Snead APPLICANT: _____
ADDRESS: 155 Stanley Rd Statesville NC APPLICATION DATE: 5 28 99 DATE EVALUATED: 6 1 99
PROPOSED FACILITY: 3Bd Rm PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.8 Ac
LOCATION OF SITE: Hwy 90 W on left past Liparod Springs Lot 2 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 1%	0-30	SBK C	FI SS SP SEXP					PS .3
		30-48+	SBK C mica flecks	FI-FR SS SEXP					
2	L 1%	0-36	SBK C	FI SS SP SEXP					PS .3
		36-48+	SBK C SAP inclus	FR SS SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 sqft	5ma
System Type(s)	Conv Conv	Low Pressure Pipe
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Potter
OTHER(S) PRESENT: _____