11523

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR New Unity A.R. Church DATE 6-26-70 PERMIT NO. 9K-42

PHONE: Business _____ Home _____

LOCATION 50 W TR on South Brch Rd - TL 1st Paved Rd Cross Roads Church on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Clay Loam - Sandy Subsoil
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	5 min.
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2-6 % Slope
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10'
			Rock or other impervious formations	None


Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 100 Linear Ft. 3
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (4



Plot of System

Installed by Henry Lee

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/26/70

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold