DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9K-1-A-4
DATE: 8-31-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: JAMES E. & SHIRLEY HITT, JR
ADDRESS: 1216 RADIO ROAD
STVL, NC 28677
OWNER ✓ AGENT: PHONE: 878-9664
APPLICATION DATE: 8-22-95 DATE EVALUATED 8-31-95
PROPOSED FACILITY: 4BR W/ 9 PERSONS
PROPERTY SIZE: 0.991 ACRE
LOCATION OF SITE: OAK HILL S/D #4
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other BOTH EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. S
	4%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
2	L	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. S
	3%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS
SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3
EVALUATED BY: S. HERRICK OTHER(S) PRESENT: JAMES & SHIRLEY HITT, BRAD STUART
COMMENTS:

0003675