DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

Permit # 100495

# SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Honeycutt APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/29/01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: X
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other (873-2495 → Gary Sloan)
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut (828) 632-7192 Alex Co. School
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed (828) 632-7063

| PROFILE # | .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFIL CLASS & LTAF |
|---|---|---|---|---|---|---|---|---|---|
| 1 | 6% Linear | 0-4 | sl | Fr NS NP MEXP | | | | | PS .35 |
| | | 4-10 | scl 5% mica sbk | fr ss sp SEXP | | | | | |
| | | 10-34 | cl 10% mica sbk | fr ss sp SEXP | | | | | |
| | | 34-42 | cl Heavy mica sbk | ss sp SEXP | | | | | |
| | | 42-48 | | | | | | | |
| 2 | 5% Linear | 0-5 | sl | Fr NS NP MEXP | | | | | PS .35 |
| | | 5-11 | scl Some mica sbk | fr ss sp SEXP | | | | | |
| | | 11-25 | cl Heavy mica sbk | fr ss sp SEXP | | | | | |
| | | 25-48 | cl Mica/Sap | ss sp SEXP | | | | | |
| 3 | 7% Linear | 0-7 | sl | NO NP NEXP | | | | | PS .35 |
| | | 7-14 | scl 5% mica sbk | fr ss sp SEXP | | | | | |
| | | 14-36 | cl Heavy mica sbk | fr/fi SEXP | | | | | |
| | | 36-48 | cl Heavy mica/Sap | fr SEXP | | | | | |
| 4 | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | PS | PS |
| System Type(s) | Conv. Conv | Conv, Conv |
| Site LTAR | .35 | .35 |

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____

# LEGEND

*use the following standard abbreviations*

| LANDSCAPE POSITION | GROUP | SOIL TEXTURE | CONVENTIONAL .1955 LTAR | LPP .1957 LTAR | MINERALOGY/ CONSISTENCE | STRUCTURE |
|---|---|---|---|---|---|---|
| CC (Concave Slope) | I | S (Sand) | 1.2 - 0.8 | 0.6 - 0.4 | NEXP (Non-expansive) | G (Single Grain) |
| CV (Convex Slope) | | LS (Loamy Sand) | | | SEXP (Slightly Expansive) | M (Massive) |
| D (Drainage Way) | | | | | EXP (Expansive) | CR (Crumb) |
| DS (Debris Slump) | II | SL (Sandy Loam) | 0.8 - 0.6 | 0.4 - 0.3 | | GR (Granular) |
| FP (Flood Plain) | | L (Loam) | | | | SBK (Subangular Blocky |
| FS (Foot Slope) | | | | | | ABK (Angular Blocky) |
| H (Head Slope) | III | SI (Silt) | 0.6 - 0.3 | 0.3 - 0.15 | | PL (Platy) |
| L (Linear Slope) | | SICL (Silty Clay Loam) | | | | PR (Prismatic) |
| N (Nose Slope) | | CL (Clay Loam) | | | | |
| R (Ridge) | | SCL (Sandy Clay Loam) | | | MOIST | WET |
| S (Shoulder Slope) | | SLC (Silt Loam Clay) | | | | |
| T (Terrace) | | | | | VFR (Very Friable) | NS (Non-sticky) |
| | IV | SC (Sandy Clay) | 0.4 - 0.1 | 0.2 - 0.05 | FR (Friable) | SS (Slightly Sticky) |
| | | SIC (Silty Clay) | | | FI (Firm) | S (Sticky) |
| | | | | | VFI (Very Firm v. Very Sticky) | VS (Very Sticky) |
| | | O (Organic) | None | | EFI (Extremely Firm) | NP (Non-plastic) |
| | | | | | | SP (Slightly Plastic) |
| | | | | | | P (Plastic) |
| | | | | | | VP (Very Plastic) |

*NOTES*

| | |
|---|---|
| *HORIZON DEPTH* | In inches below natural soil surface |
| *DEPTH OF FILL* | In inches from land surface |
| *RESTRICTIVE HORIZON* | Thickness and depth from land surface |
| *SAPROLITE* | S(suitable) or U(unsuitable) |
| *SOIL WETNESS* | Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation |
| *CLASSIFICATION* | S (Suitable), PS (Provisionally Suitable), or U (Unsuitable) |

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft$^2$

**Show profile locations and other site features (dimensions, reference or benchmark, and North).**

