ON-SITE WASTEWATER SECTION

COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

470684 7717

OWNER: TONYA FRUSNIGHT APPLICANT: SAME
ADDRESS: 377 AIRPORT RD / SNL APPLICATION DATE: 2-16-99 DATE EVALUATED: 2-26-99
PROPOSED FACILITY: ~~4BR/1DWCS~~ PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 6.92 ACRES
LOCATION OF SITE: LARKIN EXXON #6 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ ~~Auger~~ Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ ~~Sewage~~ ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 2%	0-36	SBK / C	FR-S / SEXP	—	—	—	—	PS 0.25
		36-48	SBK / CL	FR / SEXP					
2	L 3%	0-48	SBK / C	FR-S / SEXP					PS 0.25
3	L 2%	0-36	SBK / C	FR-SS / SEXP					PS 0.25
		36-48	SBK / CL	FI / SEXP					
4	L 3%	0-48	SBK / C	FS-SS / SEXP					PS 0.25

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: JC POTTER, ERIC & TONYA FRUSNIGHT