HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9F-3-1-7
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: KEITH BOAN OWNER: ✓ AGENT: PHONE: 876-1653
ADDRESS: 302 TREEBARK ROAD APPLICATION DATE: 6-28-95 DATE EVALUATED: 7-7-95
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR House w/ C.S.
PROPERTY SIZE: ~ 190' x 235'
LOCATION OF SITE: #7 LARKIN SLOAN
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 3%	0-8	SC	GR	1:1 / MIX	MOTTLES: 10YR7/8
		8-38	C	WSBK	1:1 / FI	1942 WETNES CONDITION S - 10YR-7/8
		38-48	C	SBK	1:1 / FI	.1943/ 1956 SAPROLITE S
						1944 RESTRICTIVE HORIZON S
						1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 GPD/FT²
2						1942 WETNES CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) 5' SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3.
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TIM ALEXANDER, BRADY FREEMAN
COMMENTS:

DRAFT