HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9F-A-12 (28
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BRYAN LEAIRD OWNER: AGENT: PHONE: 528-3581
ADDRESS: 106 DAWNWOOD LN. APPLICATION DATE: 9/11/99 DATE EVALUATED: 9/11/99
STATESVILLE NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 1.09 ACRES
LOCATION OF SITE: LOT #28 LARKIN SLOAN ESTATE
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-34	C	SBK	1:1 / FI	.1942 WETNES CONDITION S.
		34-48	C	CR	1:1 / FR	.1943/.1956 SAPROLITE MICACEOUS @ 34
						.1944 RESTRICTIVE HORIZON S.
						.1948 PROFILE CLASSIFICATION PS.
						PROFILE LTAR 0.35 GPD/FT²
2	L 4%	0-38	C	SBK	1:1 / FI	.1942 WETNES CONDITION S.
		38-48	C	CR	1:1 / FR	.1943/.1956 SAPROLITE MICACEOUS @ 38
						.1944 RESTRICTIVE HORIZON S.
						.1948 PROFILE CLASSIFICATION PS.
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: BRIAN & LORIE LEAIRD
COMMENTS:

DRAFT

0009900