DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

4707 77 5918 (PT)

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: MICAH CHILDS APPLICANT: SAME
ADDRESS: P.O BOX 7395 STVL, NC 28687 APPLICATION DATE: 3-9-00 DATE EVALUATED: 4-4-00
PROPOSED FACILITY: 3BR SW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 35 ACRES
LOCATION OF SITE: END OF SUE LANE OFF ABNER ROAD PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 18%	0-12	SBK / C	FI / SEXP	MOTTLED				PS 0.3
		12-28	SBK / CL	FR / SEXP					
		28-48	WSBK / SIL	VFR / SEXP					
2	L 18%	0-10	SBK / C	FI / SEXP	MOTTLED				PS 0.3
		10-30	SBK / CL	FR / SEXP					
		30-48	SBK / SIL	VFR / SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	I	I
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HUSPECK
OTHER(S) PRESENT: MICAH CHILDS