IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Timothy Johnson DATE 2/20/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115N., T.L. on 1593, T.L. on 1554, T.R. on Harris Bridge Rd #1570, cross bridge & Turn on second drive on left. 1st house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 1 No. Bathrooms _____

Garbage Disposal Unit	Yes	✓	No	( )	
Auto. Dishwasher	Yes	✓	No	( )	
Auto. Wash. Machine	Yes	✓	No	( )	
Site Suitable	Yes	✓	No	( )	

Lot Area 2 Acres


Character & Porosity of Soil Cecil Clay Loam

Percolation Rate 60 Min

Topography Good

Depth to Water Table 70 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of [redacted] 4 Panels = 240 ft long
[redacted] Ft 320 [redacted] Side Wall

Depth of Stone in Lines _____

Water Supply: Individual ✓
Public ( )

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

Andrew E. Causey - Sanitarian I
William M. Howard - Sanitarian II

CERTIFICATE OF COMPLETION BY Kellie W. Johnson R.S. Supv. Sanitarian DATE 2/20/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold