11630

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BENJAMIN A. LEWIS, JR DATE 7/24/90 PERMIT NO. 90-A-52

PHONE: Business _____ Home _____

LOCATION 90 W TR MIDWAY RD TL HARRIS BRIDGE RD GO APPROX 1 MILE - DBLE-WIDE ON (R) IN WOODED AREA

SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ SECTION OR BLOCK NO. _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 5 AC

Character & Porosity of Soil Prev. Suitable
Percolation Rate 2
Topography 2-6%
Depth to Water Table 10'
Rock or other impervious formations NONE NOTED

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by JAMES HUDDLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY GLENN Fox, JR

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Herrick / GLENN Fox, JR DATE 7/24/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold