DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: McDowell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shelia Head
ADDRESS:
APPLICANT:
APPLICATION DATE: 3.14 2000 DATE EVALUATED: 4-10-2000
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE: 2 Ac
LOCATION OF SITE: Midway Road (Te) Hanks Bridge Drive on Right PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other Past Bridge in Field
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	S 12-15%	0-6	CL						PS .3+
		6-28	SRS C/Micaceous FR	SS SSEP					
		28-50	G-CR C/Saprolite FR-VFR						
2	L-S 18-20%	0-4	CL						PS .3
		4-24	C	FR SS SP-SP					
		24-36	C/SAP Inclusion						
		36-40+	SAP w/ Weathered Rock						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)	Conv. Gravity	
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Potter
OTHER(S) PRESENT: