Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4709-43-1101
Lot #: 2
Permit #: 220710
AppID:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: TODD LIPE
Applicant: OAKEWOOD HOMES
Address: 1084 HARRIS BRIDGE RD. STONEY POINT
Date Evaluated: 9/22/2016
Proposed Facility: SFR
Design Flow (.1949) 360
Property Size: 1.4 AC
Location of Site: SAME
Property Recorded: YES
Water Supply: [X] Public [ ] Individual [ ] Well [ ] Spring [ ] Other
Evaluation Method: [ ] Auger Boring [X] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
PIT 1	LINEAR 5%	0-33	RC,M,SBK	SS	NA	50"	NA	50"+	.3
		33-50	RCL,M,SBK	SS					
PIT 2	LINEAR 5%	0-39	RC,M,SBK	SS	NA	48"	NA	48"+	.3
		39-48	RCL,M,SBK	SS					
PIT 3	LINEAR 5%	0-34	RC,M,SBK	SS	NA	48"	FEW INC 19-48"	48"+	.3
		34-48	RCL,M,SBK	SS					
PIT 4	LINEAR 5%	0-28	RC,M,SBK	SS	NA	48"	BAND OF MINERAL @26"	48"+	.3
		28-48	RCL,M,SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	G-25% RED	SAME
Site LTAR	.3	.3

Other Factors (.1946):
Soil Evaluation By: BEN ALDRIDGE
Others Present: SEAN ABEE
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: SEAN ABEE