IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10955

OWNER OR CONTRACTOR Dale Moore DATE 8/90 PERMIT NO. MK-A-77

PHONE: Business _____ Home _____

LOCATION 1577 Pisgah & Johnson Rd Private Drive Yemi
from power right away 1/4 on Left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Pro Suitable
Percolation Rate 3 Bpf
Topography Rolling
Depth to Water Table None
Rock or other impervious formations None


Lot Area 8 AC

_____ Basement with Plumbing Tankless _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 240
Depth of Stone in Lines 12

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by A1 Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/30

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold