DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Steven Rhyne APPLICANT: Same
ADDRESS: 880 Pisgah Road Stanley APPLICATION DATE: _____ DATE EVALUATED: 4/27
PROPOSED FACILITY: 3BRMH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.73
LOCATION OF SITE: _____ PROPERTY RECORDED: Y
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	R. Side 2%	0-12	SaL	fr SS SO SEXP					PS .35
		12-16	cl	fi SP					
		16-30	cl	fi SP					
		30-49	Sap (a) SI	fr NSSO NEXP					
2	R. Side 42%	0-14	SaL	Fr SEXP					PS .3
		14-26	cl	fi SEXP					
		26-42	cl	fi SEXP					
		42-46	Sap (a) SI	fi NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity, 25% Reduc.	Gravity, 25% Reduc.
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____