PROPERTY ID #: _____
COUNTY: _____

ON-SITE WASTEWATER SECTION

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: John Childress APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	8% Nose Terrace	0 to 18 18"	CL Rock + Saprolite			U			U
2	10%	0 to 18 18 to 36 36" +	CL Clay + Saprolite Rock + Saprolite		PS	PS	PS	PS	PS .3
3	10%	0 to 20 20 to 42	CL Clay + Saprolite		PS	PS	PS	PS	PS .3
4	17% Nose	0 to 36 36" +	SCL Rock + Saprolite		PS	PS	PS	PS	PS .35

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)	Conv. Gravity	
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. C. Moore
OTHER(S) PRESENT: John Childress