00781

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR MORRIS WILSON DATE 1-9-85 PERMIT NO.

PHONE: Business Home

LOCATION Buffalo Shoals Rd. west, T.L. on Laurel Cove Rd. - go on down to Laurel Cove Dev. - lot on (R).

SUBDIVISION NAME LAUREL COVE LOT NO. 5 S. R. No. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Ample

Character & Porosity of Soil Sandy Loam Suitable
Percolation Rate .4 gal/sq. ft.
Topography 6-10%
Depth to Water Table 10+
Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 280 Linear Ft. 140
Depth of Stone in Lines 12" SAND
Water Supply: Individual (✓)
Public ( )
2 ROWS OF T+J PANELS, EACH ONE 70'X2'.
Installed by Eddie Young

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: 24" panels used.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 1-9-85.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold