IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Weymouth Moore DATE 11-22-74 PERMIT NO. _____

PHONE: Business 872-4144 Home _____

LOCATION Buffalo Shoals Rd TO E. monbo Rd. T.to. T.R. into Spring Shore to to Stop Sign T.R. 2nd Lot on L. S. R. No. _____

SUBDIVISION NAME Spring Shore LOT NO. 49 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 109 X 218


Character & Porosity of Soil Sandy Clay Loam

Percolation Rate _____

Topography Slope to L Rear

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Harlen Lackey

IMPROVEMENTS PERMIT BY Andrew E. Causey

COMMENTS: House not started at time of inspection

CERTIFICATE OF COMPLETION BY E. G. Stutenson DATE 11-22-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold