IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E. F. Valentine DATE 2-11-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. T.L. on 1437 - T.L. into Sub. Division - Last house at Cul-De-Sac S. R. No. _____

SUBDIVISION NAME River Hills Estates LOT NO. 35 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000ft +-


Character & Porosity of Soil Cecil Sandy Clay

Percolation Rate _____

Topography Slope to Lake

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by A. E. Harwell Const. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts should be diverted away from Tank and drainfield. Small Maple tree should be moved away from edge of drainfield. Septic Tank Contractor to have a Minimum of 20 inches of Cover over all parts of system.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2-11-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold