IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Gilmore DATE 4 Nov 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd Pond East Mocks Rd. T. L on Rd 1437. T. L. into Pine Hill. House on Point in off S. R. No. _____

SUBDIVISION NAME Pine Hill Estates LOT NO. 42 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20,000 sq ft

Character & Porosity of Soil Cut Clay loam. CC C2
Percolation Rate Ran average
Topography L-102 slope
Depth to Water Table ok
Rock or other impervious formations L



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 969 Linear Ft. 323
Depth of Stone in Lines 10" plus
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Aubin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wayne Aubin DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold