# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FANFFALL BOLERO DATE 10-20-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west, go on past Sam Ostwalt Rd. & T.L. on S.R. 1437 - beg. left toward end of st. - house on left at end. S. R. No. _____

SUBDIVISION NAME River Hill Estates LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Character & Porosity of Soil cecil clay
Percolation Rate .6 all sq ft.
Topography 15-25%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area 20,000 sq ft.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 240
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )

Installed by Paul Frye
I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Recommended to install well tile over inlet compartment of septic tank & extend it to ground level & cover with cap. The purpose being for easy access in order to pump tank.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 10-20-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold