Ken Cole - Bldr

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ken Coulter DATE 5-28-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION River Hills Estates Off of Buffalo Shoals Rd. Lakewood Trail - 1st House on L. S. R. No. _____

SUBDIVISION NAME River Hills Estates LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 Sq ft


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slope to Lake

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank ~~1250~~ 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stutenson DATE 5-28-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold