08733

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GARY THOMAS DATE 3-10-89 PERMIT NO. 17A.

PHONE: Business _____ Home _____

LOCATION Pinesville Rd. off Shelton Ridge Rd. - go approx. two miles S.R. into dev. - near end of Hillcrest St.

SUBDIVISION NAME RIDGE CLIFF DEV. LOT NO. 3 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3 Acres

Character & Porosity of Soil Loam Sandy
Percolation Rate 1" per 10 min.
Topography Rolling
Depth to Water Table 18+
Rock or other impervious formations None observed

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1250 PLUS 1250 PUMP TANK
Nitrification Field: No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Well is 50'+ from dist. bsp.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-20-89.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold