MICHAEL ZYLAK (C)

IREDELL COUNTY HEALTH DEPARTMENT

This permit replaces #101200 of 9-28-01 634-8 885

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 128613 PIN# 4710-69-2090

OWNER OR CONTRACTOR LAKE NORMAN REALTY PHONE: Business (704) 663-3655 Home DATE 5-12-05

ADDRESS 522 RIVER HIGHWAY MOORESVILLE NC 28117

LOCATION BUFFALO SHOALS RD TL LAUREL COVE TL ISLAND TERRACE TL RIVER RIDGE ON LEFT

SUBDIVISION RIVER RIDGE BLOCK / SECTION LOT 5 LOT AREA 1.78 SITE CLASS PS DESIGN FLOW 480 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1000 Gallons; STB 794 Date 7-3-07

Pump Tank: 1000 Gallons; PT 283 Date 8-29-07

Pump Make: GOULDS Model WE0012HO Serial No.

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 270

No Lines 4 Trench Width 36" Max Trench Bottom Depth 30" Gravel Depth 24" SAND

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LP PANEL 50% REDUCTION

Repair System Description: LP PANEL 50% REDUCTION

Maintenance Agreement Required: ☑ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments/Conditions:

IF 36" TRENCHES ARE TO BE INSTALLED THEY MUST HAVE 9' CENTERS WIDE

Comments/Conditions: 62 PANELS = 223 Gallon Dose Set on Bell Siphon

Soil Scientist DATA IS WRONG

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN

BY ASHLEY ROLLANS, LSS

ROLLANS SOIL & ENVIRONMENTAL SERVICES

PROJECT NO. 01-1097

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit – not to exceed sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

12-18-07

...mit/any unauthorized ... ...ion to Construct is void.