12655

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Les Charnock DATE 11-7-91 PERMIT NO. 30-3-B-5

PHONE: Business _____ Home _____

LOCATION East monbo Rd To end TL into Heronwood Past catspaw next st TR at end _____ S. R. No. _____

SUBDIVISION NAME Heronwood LOT NO. 31 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prev. Suitable
Percolation Rate .4
Topography 6 to 10%
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area: _____

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by E. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Lake Norman

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 11-7-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold