IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR F. B. Clark DATE 10-8-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 S. to E. Mombo Rd T.R. T.L. at Bethel Church. T.R. on Rd 1331. House on R. on Lake _____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 18 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil _____
Percolation Rate No Perk Test
Topography Steep Slope
Depth to Water Table Unk
Rock or other impervious formations Possible

Lot Area _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harry Reep.

IMPROVEMENTS PERMIT BY William M. Howard

COMMENTS: House under Construction Prior to Sept 1, 1973

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2-14-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold