5634

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Douglas Pritchard DATE 12-2-88 PERMIT NO. A-17

PHONE: Business _____ Home _____

LOCATION East Mando Rd off old mtn Rd Go almost to end T.L. into Dev follow St. Past catspaw TR on 2nd St. R. No. Lots on R. at bottom of hill

SUBDIVISION NAME Heronwood LOT NO. 8 & 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Character & Porosity of Soil Prov. Suitable
Percolation Rate 14
Topography 6 to 10%
Depth to Water Table 10
Rock or other impervious formations none


Lot Area Ample

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement

1250 Pump
Size of Tank 1250 S.T. Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public ( )



Plot of System

Installed by James Hutler + Custom Building Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

Steve Brown Checked all but Alarm + Filling out Cert. of Compl.

COMMENTS: Zoeller Pump E-165 1 HP Pump will Pump 50 gpl/min at Approx 50' Total Head

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-2-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold