DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____ SHEET____OF____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Hinshaw Shoaler
ADDRESS: _____
OWNER___AGENT:___PHONE: _____
APPLICATION DATE:_____DATE EVALUATED_____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 33, 34, 35, & 36
WATER SUPPLY: On-site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear 20	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 18	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
		18 to 48	SCL	weak SBK	Lil			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - 135
2	linear 40	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 20	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
		20 to 48	SCL	weak SBK	Lil			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - 135
3	linear 30	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 24	C	SBK	Lil			.1943 Depth/.1956 Sapr. - N/A
		24 to 48	CL	SBK	Lil			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - 135
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Y/N OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948) PS
SYSTEM TYPE_____ LONG-TERMACCEPTANCE RATE(S) 135
EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Doug Mattison
COMMENTS: _____