HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: High Shoals Dev. Inc OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-25-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Gray Rock S/D
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	4-6% L	0-4"	cl	gr	1:1 / vfr	.1942 WETNES CONDITION -	P.S
		4"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE -	NA
						.1944 RESTRICTIVE HORIZON -	NA
						.1948 PROFILE CLASSIFICATION -	P.S.
						PROFILE LTAR -	.35
2	4-6% L	0-5"	cl	gr	1:1 / vfr	.1942 WETNES CONDITION -	P.S.
		5"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE -	NA
						.1944 RESTRICTIVE HORIZON -	NA
						.1948 PROFILE CLASSIFICATION -	P.S.
						PROFILE LTAR -	.35
3	4-6% L	0-3"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION -	P.S.
		3"-42"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE -	42"-↑
		42"-↑	saprolite			.1944 RESTRICTIVE HORIZON -	NA
						.1948 PROFILE CLASSIFICATION -	P.S.
						PROFILE LTAR -	.35
4						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
5						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1948 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY Michael L Dennis OTHER(S) PRESENT
COMMENTS:

DRAFT