DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Doug Madison APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 3BR/House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .91 Ac.
LOCATION OF SITE: Curry Rock Lot #8 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) Shoals .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Concave 19%	0-10"	SE	VFR NS NP NE+P					PS .35
		10-34"	SE some mica	fr ss sp SE+P					
		34"-48"	SE/L some mica	fr ss sp SE+P					
2	Concave 20%	0-8"	SE	VFR NS NP NE+P					PS .35
		8-14"	SE w/SaL	SFR SS SP SE+P					
		14-48"	SE w/Sa some mica w/SaL	fr ss sp SE+P					
3	Concave 10%	0-4	SE & L	VFR NS NP NE+P					PS .35
		4-12	C/SE w/SaL	FR SS SP SE+P					
		12-24	C/SE w some mica SaL	fr ss sp SE+P					
		24-48	SE w/SaL mica	fr ss sp SE+P					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv	Gravity Pump 25% Red.
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: Doug Madison