Hatteras Pools

CI

2637883 100 YD 96

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 109873 PIN# 4711-13-3783 480

OWNER OR APPLICANT RICK WILSON PHONE: Business 704-902-2343 Home 704-838-0491 DATE 5-19-08

ADDRESS 2428 FALCON LANE Statesville NC 28625

LOCATION BUFFALO SHOALS WEST ① WINDING WOOD RD River AF Ind on RH RH CUL-DE-SAC

SUBDIVISION Ridgewood BLOCK / SECTION ____ LOT 19 LOT AREA 2.02AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25spd

Septic Tank: 1000 Gallons: STB 1000 Date 5-27-08
Pump Tank: ____ Gallons: PT ____ Date ____
Pump Make: ____ Model ____ Serial No. ____
Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480'
No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☒ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: LP 50% REDUCTION
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons 8
☐ Business No. Employees ____
☐ Other ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: ① See Attached Comments on System Design. ② Old SOIL NOTES From B. Freeman program Specialist at the time was used & new was performed also.

Comments/Conditions: OFFSITE Fill-IN MATERIAL BUILDING OK'D CHANGES RW

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LORNE COOK, RS.I

AS BUILT SKETCH

Septic Lines 20' BEHIND MARKERS P/U AS DRAWN DUE TO EASEMENT AS PER ATTACHMENT. SYSTEM 100' + FROM WELL. USED ENP CAPS FOR DISTRIBUTION

Location of the proposed 14'X30' Pool addition does not appear to impact the existing on-site septic system or well.**NOTE:

REHS Date: 06/12/14
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: RW Wilson date 5-27-08 Installed by: Castle Thompson Bros date 6-6-08

Improvement Permit by: ____ date 5-14-08 Operation Permit by: ____ date ____

Authorization to Construct by: ____ date 5-14-08 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK