SHEET____OF____

DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#:
DATE:
COUNTY:

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: High Shoales
ADDRESS:
OWNER__AGENT:__PHONE:
APPLICATION DATE:____DATE EVALUATED
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lot 41 Gary Koch
WATER SUPPLY: On-site Well____Comm. Well____Public____Other____EVAL. METHOD: Auger Boring____Pit____Cut____

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	Linear	24 to 48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	10%							.1948 Profile Class. - PS
								Profile LTAR - .3
2		0 to 4	L	GR				.1942 Wetness Cond. - N/A
	Linear	4 to 30	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		30 to 48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	10%							.1948 Profile Class. - PS
								Profile LTAR - .3
3	Linear	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 18	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	10%	18 to 30	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	to	30 to 48	B/C	very weak	1:1			.1948 Profile Class. - PS
	15%							Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) 1/2 OTHER FACTORS (.1946)____SITECLASSIFICATION (.1948) PS

SYSTEM TYPE____LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Doug Madison

COMMENTS: