IK500 KIM

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (C1) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTIO

PERMIT# 072282 PIN# 4711 32 6122 4711-20-1619 DATE 11-5-99

OWNER OR CONTRACTOR LAKE NORMAN PROPERTIES PHONE: Business 847-6006 Home

ADDRESS P.O. BOX 1627, MATTHEWS, NC 28106

LOCATION BUFFALO SHOALS RD, TL LAUREL COVE RD, TR HARBORGATE, TR HARBORWATCH, TL HARBOR RIDGE, TL HARBOR CI

SUBDIVISION HARBOR WATCH BLOCK / SECTION II LOT 136 LOT AREA 1.88 ACRES SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 0.25 spd/sf

Septic Tank: 1000 Gallons; STB 794 Date 1-25-03

Pump Tank: 1000 Gallons; PT 283 Date 1-29-03

Pump Make: MYERS Model MESOS-11 Serial No.

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 240

No Lines FIVE Trench Width 24" Max Trench Bottom Depth 38" Gravel Depth SAND 6"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LOW PRESSURE PPBPS

Repair System Description: LOW PRESSURE PPBPS

Maintenance Agreement Required: ☑ Yes ☐ No

☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2 No. Employees

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supp ☑ Individua ☐ Public ☐ Commu WELL

Comments:/Conditions:

Comments:/Conditions: SEPTIC TANK W/ RISERS INSTALLED USING "ZABEL" FILTER

INITIAL SITE SKETCH

① INSTALL 50% REDUCTION SYSTEM USING FIFTY-FIVE (55) PPBPS PANELS IN FIVE EQUAL LENGTH LINES ON CONTOUR AS SHOWN ON THE ATTACHED PLAN. (GERALD N. GRANT & ASSOC. PROJ. NO. 96017-LOT 136)

② INSTALL LINES IN ACCORDANCE WITH THE GUIDELINES SET FORTH IN .1956 (5).

③ SYSTEM TO BE INSTALLED ACCORDING TO ATTACHED PLAN IN REFERENCE TO PUMP, IN-LINE PUMP FILTER W/ SOCK & SYSTEM HEAD REQUIREMENTS.

④ PPBPS PANELS TO BE INSTALLED ACCORDING TO MANUFACTURERS SPECIFICATIONS.

⑤ CERTIFIED MANAGEMENT ENTITY SHALL BE CONTRACTED WITH PRIOR TO ISSUANCE OF OPERATION PERMIT.

AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO INITIAL SITE SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Impro

Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Daniel V. Grant, AGENT date 11-5-99

Improvement Permit by: STEVE HEDRICK date 11-5-99

Authorization to Construct by: STEVE HEDRICK date 11-5-99

Installed by: CURT DUNNING 9-2-03

Operation Permit by: STEVE HEDRICK date 9-2

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK