Harbor watch
Section I lot 37

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System
Scott Creamer
224 South Harbor watch
Statesville, N.C.
28677

Date of Inspection
5-6-10

Permit Number
13666 1

County
Iredell

System Classification
IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner
Same

Phone: (704) 873-2171

Phone:

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
NO Risers accessible need Riser over Septic Tank
S Signs of Infiltration
S Structurally Sound
S Landscape Position
NO Filter Cleaned

PUMP
YES Pump present and operating
34 Design GPM
34 Actual GPM
100 % Efficiency
YES High water alarm operating properly
S Pipework in good condition
S Control panel in good condition
S Control floats operating properly
S Sumps and float free
S Effluent free and clear of solids

DRAIN FIELD
S No effluent surfacing
S Surface water diverted
S Line cover maintained properly
S Protected from traffic
S Distribution devices operating properly
S Repair area reserved

Date 5-6-10
LOW PRESSURE PIPE SYSTEM
S Turnups, cleanouts, valves located and protected
S Laterals free of excess solids
YES Laterals flushed
Pressure Heads

	Design head	Adjusted head
Line 1	2	2
Line 2	2	2
Line 3	2	2
Line 4	2	2

COMMENTS

Compliant ✓ Noncompliant ___
Signature J.C. Moore

MOORE'S ENVIRONMENTAL SERVICES
1227 TROUTMAN DRIVE
STATESVILLE, NC 28625
HOME: (704) 873-2171
CELL: (704) 902-1122 FAX: (704) 873-9928

Dear Scott Creamer :

According to my records, your Type IV-A septic system at 224 South Harborwatch Dr. Statesville is past due for a renewal on the maintenance contract for the time period of November 2010 to November 2011.

I will need to be contacted by you if you would like to renew your maintenance contract with my company. If I don't hear from you by Dec. 31 2010, I will assume you have made other arrangements and no longer need my services.

According to the North Carolina Department of Environmental Health law #15A.NC, Admin. Code #18A.1961, I am required to notify the Iredell Health Department that I am no longer the operator for your system if you choose not to renew with my company.

Thank you for your past business and hopefully we can continue to do business in the future.

Sincerely,

J. C. moore

J. C. Moore
NC Registered Sanitarian (Cert. #372)
Subsurface System Operator (Cert. #985357)
NC Onsite Wastewater Inspector (Cert. #12331)