DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4711 716122

OWNER: LARRY McCOURT APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 11-5-01
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: HARBOR WATCH 6 / 146 PROPERTY RECORDED: ____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	14% LSS	0-5"	scl, wk, gr	f, ns, np, vfr		>48"			PS .3
		5-36"	c, med, sbk	f, ss, sp, sep					
		36-48"	c sap inct	f, ss sp sep					
2	14% LSS	0-5"	scl, wk, gr	f, ns, np, vfr		>48"			PS .3
		5-36	c, med, sbk	f, ss, sp, slxp					
		36-48"	c sap mix	f ss sp sep					
		48"	ROCK						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	600 GAL / 25% / SPLIT	600 GAL / 25% / PANEL
Site LTAR	.5	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: ____