DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: William Troutman II OWNER__ AGENT:__ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other_____ EVAL. METHOD: Auger Boring____ Pit____ Cut____

PROFILE #	.1940 LANDSCP POS./ SLOPE%	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	[redacted]	0 to 14"	SL	GR				.1942 Wetness Cond. - N/A
		14 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	linear	24 to 36	CL	~~SBK~~ SBK	1:1			.1944 Restrictive Hori. - N/A
	10%	36 to 48	S/C			7.5YR	5	.1948 Profile Class. - PS
								Profile LTAR - .3
2		0 to 12	SL	GR				.1942 Wetness Cond. - N/A
	linear	12 to 18	SC	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		18 to 36	SCL	SBK	1:1			.1944 Restrictive Hori. - N/A
	10%	36 to 48	S/C			7.5YR	4	.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Comunity LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: J. C. Moore OTHER(S) PRESENT: William Troutman II

COMMENTS: _____