* PERMIT REPLACES #074037 ISSUED 11-20-98, NOW VOID — FAST TRACK PERMIT

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 — MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 128482 PIN# 4711-31-5285 DATE 5-11-05

OWNER OR CONTRACTOR PRESTIGE PREMIER HOME BUILDERS, INC PHONE: Business (704) 528-3999 Home

ADDRESS PO BOX 749 TROUTMAN, NC 28166

LOCATION BUFFALO SHOALS RD TL LAUREL COVE RD TR HARBORGATE TL HARBOR WATCH TR NORTHSTONE ON RIGHT

SUBDIVISION HARBOR WATCH BLOCK / SECTION V LOT 100 LOT AREA 2.154 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 0.30 GPD/FT²

Septic Tank: ~~1000~~ 1500 Gallons; STB 339 Date 12-23-05

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 400

No Lines THREE Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: GRAVITY 25% REDUCTION

Repair System Description: LP PANEL 50% REDUCTION

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other _____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:

Comments:/Conditions:

Red Filter w/risers

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN

BY ASHLEY ROLLANS, LSS

ROLLANS SOIL & ENVIRONMENTAL SERVICES

PROJECT NO. 01-1099

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 5-11-05 Installed by: Kurt Dunning

Improvement Permit by: Christopher M. Sherrill RS, LSS date 5-11-05 Operation Permit by: _____ date 2-2-06

Authorization to Construct by: Christopher M. Sherrill RS, LSS date 5-11-05 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

Use Permit #171298 for detached garage.